

# Advances in Mercury Control Technology for Industrial Sources






**July 9, 2008**



# Presentation Outline

- **MACT History – Activated Carbon**
- **Factors Controlling Mercury Emissions**
- **Case Study**
- **Activated Carbon Supply**

# What is Activated Carbon?



# MACT Overview

	NESHAP						
	MWC MACT	HWC MACT	Foundry MACT	2° Al Smelter MACT	Portland Cement MACT	Boiler MACT	Coal-Fired Electric Utilities (no MACT)
Regulation Issued	1995	2001	2003	2003	2006	<b>VACATED</b>	<b>VACATED</b>
Hg	✓	✓	✓			✓	✓
Dioxins / Furans	✓	✓		✓	✓		

# Original Boiler MACT

- **BACT for Existing Sources**

- **Large Units: heat input > 10 mmbtu/hour**

**Non-mercury metallic HAP**

**Fabric Filter**

**Mercury**

**Fabric Filter**


**Inorganic HAP**

**Scrubbers**

**Organic HAP**

**none identified**

# Estimated Hg Emissions by Source



Total Emissions - 1990 = 221 tons  
Total Emissions - 2002 = 119 tons

# Plant Dynamics Affecting Hg Capture

- **Coal Type**
- **Configuration of APCD**
- **Boiler efficiency – unburned carbon (UBC) in fly ash**


# Key Factors Affecting Hg Capture

## Coal Burned in Industrial Boilers

Coal Type	Hg ppm	Cl ppm	S Wt. %	Ash Wt. %	HHV BTU/lb
Bitum.	0.11 (0.04 - 0.28)	1033 (48 - 2730)	1.69 (0.55 - 4.1)	11.1 (5.4 - 27.3)	13,203 (8646 - 14014)
Sub-Bit.	0.07 (0.02 - 0.14)	158 (51 - 1143)	0.5 (0.22 - 1.16)	8.0 (4.7 - 26.7)	12,005 (8606 - 13168)
Lignite	>0.11	188 (133 - 233)	1.30 0.8 - 1.42	19.4 12.2 - 24.6	10,028 (9487 - 10702)

# Possible APCD in a Coal Fired Utility Plant

Industrial Boilers are Similar



# APCD Affect on Hg Capture

- **CS-ESP**
  - poor Hg capture (<5%) with PRB or lignite
  - about 30% removal with bituminous coals
- **Fabric Filter**
  - up to 90% mercury capture with bituminous coals
  - low Hg capture with lignite or PRB coals

# Case Study: MACT – Iron Foundry

- MACT Regulations, passed in 2003, require reduction in Hg emissions through mandatory elimination of Hg switches in scrap feed.
- NJDEP Enacted their own emission-based Hg reduction stds. Allowing no more than 35 mg/metric ton of scrap or 75% reduction. Passed in 4/07, compliance by 1/10.
- Other states expected to follow.
- Expected PAC usage ~120,000 lbs/yr per facility

# MACT – Iron Foundry

Process Monitor Hg Process Monitor Hg Process			Evaluation			Evaluation		
Activated Avg Carbon	Stack Test	Start Date	Activated Avg Carbon	Stack Test	Stack Test E.F. Date	Activated Avg Carbon	Stack Test	Stack Test E.F. Date
ug/m <sup>3</sup>	ug/m <sup>3</sup>	D	ug/m <sup>3</sup>	ug/m <sup>3</sup>	ug/m <sup>3</sup>	ug/m <sup>3</sup>	ug/m <sup>3</sup>	ug/m <sup>3</sup>
124OFF	5.7	26	124OFF	5.7	26	124OFF	5.7	26
131ON	3.56		131ON	3.56		131ON	3.56	
132OFF	6.11		132OFF	6.11		132OFF	6.11	

85%

Health and Safety Conference Society – 19<sup>th</sup> Environmental Health and Safety Conference  
 Nashville, TN October 7-10, 2007 – Nashville, TN October 7-10, 2007 – Nashville, TN October 7-10, 2007 – Nashville, TN

# Compliance with Activated Carbon Utility vs Typical Industrial Boiler

- **Utility**

- Salem Harbor, MA
- Generation nameplate ~ 90 Megawatts
- Steam Production ~ 600,000 lb per hour
- Air flow rate ~ 300,000 acfm
- Burn ~ 270,000 tons/year eastern bituminous coal

- **University**

- Located in Northeast US operating 4 Boilers
- Boiler Size averages 125 mmBTU/hour
- Steam Production annual average is 200,000 lb per hour
- Air flow rate ~ 100,000 acfm
- Burn ~ 75,000 tons/year eastern bituminous coal

# Compliance with Activated Carbon Utility vs Typical Industrial Boiler

			Carbon	Carbon Rate	%	Annual Carbon
Location	Coal	Equipment	Grade	(lb/MMacf)	Removal	Estimate (lbs)
Salem Harbor	Est Bit	C-ESP	Darco-Hg	10	80-90	1,500,000
University	Est Bit	Fabric Filter	Darco-Hg	~1-3	80-90	150,000 – 500,000

# Compliance Cost Comparison

	<b>Air Flow</b>	<b>Capital Expense</b>	<b>Annual Carbon Expense</b>
	(acfm)	(\$)	(\$)
<b>Electric Utility</b>	1,200,000	\$1,250,000	\$2,000,000
<b>MWC</b>	175,000	\$1,250,000	\$100,000
<b>Iron Foundry</b>	250,000	\$1,250,000	\$100,000
<b>Industrial Boiler</b>	500,000	\$1,250,000	\$300,000

# Activated Carbon Market

- **What's important going forward?**
  - Specifications
  - Performance Guarantees
  - Product Offerings
  - Demand and Supply

# Activated Carbon Specifications

## – EPRI Initiative

- Molasses, Iodine Number, BET (N<sub>2</sub>) Surface Area, Methylene Blue, BWC, Tannin Number, Phenol Number & others

– Different Carbon Base = Different Test.

– Industry needs a standardized test

# Performance Guarantees


- Individual AC companies may or may not offer
- Site specific – many variables including APCD and coal type consistency
- **Adsorptive Tests to Characterize Activated Carbon**
  - Hg Loading Capacity and Kinetics
    - Norit Americas has developed a Hg adsorption test in order to begin specifying its flue gas mercury removal products on a new CEM-based analysis.
    - Our future goal is to ensure that every lot of carbon meets expected mercury removal requirements for a standardized flue gas.

# New Products - Surface Modifications

- Low Rank Fuels (DARCO Hg-LH)
- Concrete Compatible (DARCO Hg-CC)
- SO<sub>3</sub> Resistant Carbon (Darco E-26)
  - Moderate SO<sub>3</sub> Coal and SO<sub>3</sub> Conditioning Applications
- Others in development

# Activated Carbon Demand

## Estimated Carbon Requirements by Market



\* Assumes no new technology, better estimate is 500-800mm additional lbs with Federal MACT Rule

# Activated Carbon Supply

## Norit's Supply for Future Demand

- Plant capacity is being added to meet demand
- Current powder capacity: 120 million pounds
- Permitting for 150 million additional pounds at current facilities
- Stage 2: expand to new locations
- Typical lead time for additional capacity is 12-18 months

# Expansion Update

